



NOTES:

1. THIS IS A TYPICAL SINGLE UNIT INSTALLATION PIPING DRAWING. CONSULT LOCAL CODES AND AUTHORITIES.
2. REFER TO APPROPRIATE DIMENSIONAL DRAWING OF UNIT FOR ACTUAL SIZE AND LOCATION DIMENSIONS OF PIPING AND OTHER CONNECTIONS..
3. DRAIN VALVES PIPING SHALL BE INSTALLED TO SAFE DRAIN ACCORDING TO APPROPRIATE PLUMBING CODES.
4. PIPING CONNECTIONS TO THE UNIT SHALL BE PROVIDED WITH UNIONS OR FLANGES MAINTAINING ENOUGH CLEARANCES FOR SERVICE. DIELECTRIC FITTINGS ARE SUGGESTED TO MAKE CONNECTIONS BETWEEN STEEL AND COPPER PIPING TO PREVENT GALVANIC CORROSION.
5. PIPING INSTALLATION COMPONENTS ARE SUPPLIED BY OTHERS IN THE FIELD. WATER HEATER DIMENSIONAL DRAWING SHOWS AVAILABLE PIPING COMPONENTS.
6. HOSE CONNECTIONS ON THE UNIT PIPING ARE UTILIZED DURING STARTUP CALIBRATION AND CLEANING


DIVERSIFIED
 HEAT TRANSFER INC.
 439 MAIN RD. TOWACO NJ 07082
 PHONE: (800) 221-1522 FAX: (855) 221-2400

SPC PIPING INSTALLATION DRAWING
 BRAZE PLATE WATER HEATER
 SINGLE UNIT INSTALLATION

	NAME	DATE	DWG.#	REV
DRAWN BY	SZS	10/7/24	SPC PIPING ASSEMBLY	A/1
CHECKED BY				