

NOTES:

1. SERVICE CLEARANCES TO BE IN CONFORMANCE TO NEC REQUIREMENTS. ALLOW A MINIMUM OF 36" CLEARANCE IN FRONT OF DOORS FOR SERVICING OF HEATING ELEMENTS. RECOMMENDED 24" CLEARANCE FOR OTHER SIDES OF BOILER FOR SERVICING.


4

2. MINIMUM 1" CLEARANCE TO ALL COMBUSTIBLE MATERIALS

В

<u>Service Clearance Requirements</u>

3



| А | | | | DIMENSIONS ARE SHOWN IN INCHES [CENTIMETERS] TOLERANCES ARE AS FOLLOWS UNLESS OTHERWISE SPECIFIED X.XX X.XXX X.XXX ANGULAR FINISH ±.12 ±.031 ±.0156 ±1.0° 250 REMOVE AND DEBURR SHARP EDGES AND CORNERS ALL DIMENSIONS ARE AFTER FINISH OR PLATING REFERENCE DIMENSIONS ARE SHOWN IN PARENTHESES () CRITICAL DIMENSIONS ARE SHOWN IN () | | | A39 MAIN RD. TOWACO NJ 07082 PHONE: (800) 221-1522 FAX: (718) 386-7809 | | | | | | | |
|---|-----|----------|----------------------|--|------|---------|---|--------------|----------------|---|-------|---------|-------------------------------|-----|
| | | | | | | | THIS DRAWING AND/OR SPECIFICATIONS ARE THE PROPERTY OF DIVERSIFIED HEAT TRANSFER INC. THIS CONFIDENTIAL AND PROPRIETARY INFORMATION SHALL NOT BE USED, COPIED OR REPRODUCED IN ANY MEANS AS THE BASIS FOR MANUFACTURE OR SALE OF APPARATUS WITHOUT WRITTEN AUTHORIZATION FROM OWNER. | | | EWx630-EWx960 ELECTRIC WATER BOILERS | | | | |
| | А | A FOR RE | | LEASE | JH | 1/15/25 | THIRD ANGLE PROJECTIO | N DWG. SCALE | MATERIAL SPEC: | NA | ME [| DATE | DWG# | REV |
| | REV | ECN | REVISION DESCRIPTION | | NAME | DATE | | 1:20 | | DRAWN BY | IH 10 |)/24/24 | EWx630-EWx960 Sheet 2 of 2 | A |
| | 4 | | 3 | | | 2 | | | 1 | | | | | |

В

Α